
MLC-ACCOM Indoor Climate Criteria

- Criteria based on:
 - ANSI/ASHRAE 55a
 - ISO 7726

Summary of Indoor Climate Requirements

<i>Item</i>	<i>Requirement or Criterion</i>
Air Temperature	Air temperature between Winter or Summer: 20 to 27°C (68 to 80°F)
Relative Humidity	A range from 30% minimum to 70% maximum
Air Velocity	Not to exceed 30 meters-per-minute or 100 feet-per-minute (0.5 m/s or 1.7 ft/s)
Air Exchange Rate	The rate of air change for enclosed spaces shall be at least six (6) complete changes-per-hour.